



The concept of cooling degree days was developed to relate the day's temperature to the energy demands of air conditioning. Cooling degree days are calculated using the day's average temperature minus 65° F.

Annual Cooling Degree Days

- less than 101
- 101-400
- 401-700
- 701-1000
- 1001-1500
- 1501-2000
- 2001-2500
- 2501-3500
- more than 3500

Data from the National Environmental Satellite, Data, and Information Service

