

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
JB7819 101 103	8/26/67	912	Make misc. repairs
JB7 819 101 114	8/26/67	691	Make repairs as on attached sheets, replace floor tile, window screen, and kick plates, replaster finish coat 105. F + 60 L.F. crack SH 405, replace light fixture replace insulation on hot water line, partial paint on interior.
HQ8 CM7 ONS 505		65	Misc. recurring maint and follow-up replace lampholder in flourescent fixtures
AA923 ** 15113		440	Remove tack board/coat racks in Rooms 1 thru 13, deliver to storage in Midway Park School patch holes in floor and ceiling.
AA923 ** 15125	1/3/69	543	Misc. repairs to door units, paneling, trim, bookcase etc.
AA923 ** 15121	12/20/68		Ripair hot water heat line school bldg 799'
AA923 ** 15130	1/24/69	225	Open concealed down spout in read sidewall of library during christmas season
AA923 ** 15134	2/21/69	146	Secure overhead concrete beams
AA923**15138	3/12/69		Open up build up roof for engineers inspecting , repair roof when inspection is complete.
AA0315 2319T	8/29/69	113	Install five new water coolers on existing drains and water supplies
AA023 0330 23**T	3/13/70		Repair steam line in Bldg 799
1758	11-22-74	179	Install 6' plug mold slips in 6 classrooms
1779	9-17-73	136	Install receptacle in library
1727	3-31-77	350	Rprs. to radiators connectors
1751	4-22-77		Rprs. hot water leak to soap Restroom
1714	Comp	299	Check out the heating system Central
1819	7-30-87	861	Replace (3) Doors with Hardware
1817	Comp	1077	Repr HW heating System.
1744	Comp	607	Repr leaking circulating water line.
1822	Comp	2687	misc Rprs TT
1125	2-9-96	5543	RENOVATE LOUNGE June

PURGED 99

