



REVISION 'A'  
MAY 3, 1942

WATER & SEWER CROSSINGS  
 ① - 14" Water Over 15" Sewer  
 ② - 14" Water Under Steam Line, Top W.M. El. 22.3 or Less

NOTE:  
 Valves in all cases to be located 4.0' from the Main unless otherwise specified.  
 Control elevations shown for Water Mains are top of pipe in all cases.

LEGEND  
 F.H. Fire Hydrant  
 V.F.B. Valve and Box  
 Ⓞ Water & Sewer Crossing  
 — Existing Water Mains  
 — Asbestos Cement Water Mains

PRINTED ON 1911 TRACING PAPER  
 EUGENE DITZGEN CO., CHICAGO - NEW YORK

REVISION	DATE	BRIEF	R.O. IN CHARGE	BY
"D"	6-15-43	CHANGED SERVICE TO HEATING PLANT TO AS SUPPLY. REVISED BY TRACK & DIST. NOS. AS BUILT. REVISION TO WATER DISTRIBUTION SYSTEMS EMERGENCY PLANT L.K.A.	Edw	J.W.S.
"C"	12-14-42	AS BUILT REVISION TO WATER DISTRIBUTION SYSTEMS EMERGENCY PLANT L.K.A.	Edw	J.W.S.
"B"	7-29-42	EMERGENCY PUMPING PLANT & PIPING HOOK-UP ADDED. FROM NO. ADDED.	Edw	J.W.S.
"A"	5-3-42	CONTROL ELEV. NO. 2 ADDED FOR WATER AND STEAM LINE CROSSING (BY LETTER)	Edw	J.W.S.

DRAWN BY J.W.S.  
 TRACED BY W.G.W./J.W.S.  
 CHECKED BY F.D.K.  
 CHIEF OF PMN. F.D.K.  
 IN CHARGE W.G.M.  
 DATE APR 27, 1942  
 SCALE 1" = 100'

CARR & J. E. GREINER CO.—ARCHITECT-ENGINEERS  
 DURHAM, N. C. BALTIMORE, MD.  
**MARINE BARRACKS—NEW RIVER, N. C.**  
 BUREAU OF YARDS AND DOCKS—U. S. NAVY

WATER DISTRIBUTION SYSTEM  
 & WELL TRANSMISSION MAINS  
 RECREATION GROUND  
 SECTION  
 DIVISION TRAINING AREA

ARCHITECT-ENGINEERS SPECIFICATION  
 NO. 501

APPROVED *[Signature]* SHEET  
 BY *[Signature]* RESIDENT OFFICER IN CHARGE

M.B. PROJ. NO. 2-10824  
 M.B. DWG. NO. 565

