



NOTE: SEWER LINES SHALL BE STAKED OUT AND EXAMINED BY SANITARY ENGINEER PRIOR TO CONSTRUCTION.

WATER LINES TO HAVE 3 FT. COVER AND PLACED AT ELEVATIONS SHOWN AT CRITICAL POINTS TO AVOID OTHER UTILITIES.

ONE INCH CONNECTIONS TO BE MADE WITH CORPORATION COLLS.

ALL HYDRANTS ARE TO BE VALVED ON HYDRANT STUM LINE AND 12000 GAL. ELEVATED WOOD TANK AND 1200-18000 280' 30". FOR DETAIL OF TANK & TOWER, SEE DRAWING 62 & 60.

ALL EXPOSED WATER LINES TO BE FRONT-JACKETED.

FOR DETAILS OF 3000 GAL. WATER TANKS, SEE DRAWINGS O.L.F. 101 & 102.

NOTE: REVISIONS #9, 10, 11 APPLY TO CONTACT NO. 104 V.I.S. ONLY. ALL OTHER ITEMS MARKED "END" ARE NOT TO BE CONSIDERED IN THIS CONTRACT.

APPROVED _____ DATE 12-21-42

Checked by _____ DATE 12-21-42

NOTE: This Drawing is Not to be used for construction purposes unless approved by the O.I.C.

13	5/18/44	RETRACTED	
12	3/21/44	LOCATED NEW WELL, RELOCATED PUMP LINE	R.S.G.
11	4/21/44	ADDED 100' WATER LINE NORTH OF WINGAR (6')	JOHN PETERSON
10	2/21/44	ADDED 10" WATER LINE ALONG NORTH SIDE OF TAXIWAY	
9	2/12/44	DEEP WELL AND VENTILATION HOUSE ADDED	JOHN PETERSON
8	6/16/43	ELEVATED TANK AND TOWER ADDED	
7	7/11/43	TO MEET STATE HEALTH REQUIREMENTS	RAY WELLS
6	6/23/43	ADDED SERVICES TO HANGER, NEW CONNECTIONS TO ALUMINUM	RAY WELLS
5	6/24/43	ADDED SERVICES TO DEPENSARY, OLD 10000 WOOD QUARTERS	JOHN PETERSON
4	6/24/43	ADDED TANK AND TOWER	JOHN PETERSON
3	5/12/43	NITRIFICATION BED DETAILS ADDED	RAY WELLS
2	5/12/43	WATER, SEWER & VALVES ADDED	RAY WELLS
1	5/12/43	WATER & SEWER EXPANSION ADDED	RAY WELLS
1	1/19/43	NOTE FOR 6" PORTION OF CAST IRON SEWER	RAY WELLS

Drawn by Ray Wells
 Traced by Ray Wells
 Checked by John Peter
 In Charge John Peter

OLSEN-LEITRICK-CARY & J.E. GREINER COMPANY
 ARCHITECTS AND ENGINEERS
 CHERRY POINT, N.C.

Sheet _____ of _____
 Accompanying Specification No. _____

OAK GROVE OUTLYING FIELDS
 WATER DISTRIBUTION &
 SANITARY SEWER SYSTEMS

Approved 22 Dec 1942 John Peter
 COMMANDER, (CEC) USNR
 Officer in Charge of Constr.

Drawing O.L.F. No. 202
 1/8" Drawing 300514

SCALE: 1"=100'

