

NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES  
DIVISION OF HEALTH SERVICES  
OCCUPATIONAL HEALTH LABORATORY

COMPANY: Camp Lejeune Water System  
ADDRESS: Camp Lejeune, Onslow County  
SAMPLE TAKEN ON: 02/07/85  
SAMPLE TAKEN BY: J. Fred Hill  
SUBMITTED TO LABORATORY: 02/08/85  
SUBMITTED BY: J. Fred Hill, E. Betz

DATE OF ANALYSIS: 02/08/85  
ANALYSED BY: John L. Neal, Vicki Painter

DATE REPORTED: 02/08/85

RESULTS IN PPB (ug/L)

<u>LOCATION</u>	<u>trans 1,2-DCE</u>	<u>CHCl3</u>	<u>DCBM</u>	<u>TCE</u>	<u>DBCM</u>
Bldg. 20 Res. Fin. Water	5.3	10.3	6.3	16.8	3.4
Bldg. 20 Filter Eff.#1	<2.0	6.8	4.3	<2.0	2.0
Bldg. 20 Filter Eff.#2	<2.0	9.1	5.7	3.4	3.4
Bldg. 20 Influent	<2.0	5.0	4.0	<2.0	1.5
Bldg. 670 Res. Fin. Water	<2.0	14.84	8.3	<2.0	3.6
Bldg. 670 Filter Eff.#1	<2.0	11.45	6.1	<2.0	1.2
Bldg. 670 Filter Eff.#2	<2.0	10.03	5.8	<2.0	1.2
Bldg. 670 Influent	<2.0	8.1	4.9	<2.0	1.7
MOQ 2204 Hydr. Dis. Sys.	9.0	23.92	10.74	32.4	4.5
Bldg. 5400 Ber. Man. Sch.	44.8	24.49	10.83	135.1	5.0

COMMENTS: trans 1,2-DCE is trans 1,2-dichloroethylene, CHCl3 is Chloroform, DCBM is dichlorobromomethane, TCE is trichloroethylene, and DBCM is dibromochloromethane. Samples analysed by purge and trap method utilizing Hall detector in the halogen mode.

REPORTED BY: John L. Neal

cc. Charles Rundgren, Water Supply Branch  
Mike Bell, ERO  
J. Fred Hill, ERO  
Environmental Epidemiology

CLW  
0000001516

NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES  
DIVISION OF HEALTH SERVICES  
OCCUPATIONAL HEALTH LABORATORY

COMPANY: Camp Lejeune Water System  
ADDRESS: Camp Lejeune, Onslow County  
SAMPLE TAKEN ON: 02/07/85  
SAMPE TAKEN BY: J. Fred Hill  
SUBMITTED TO LABORATORY: 02/08/85  
SUBMITTED BY: J. Fred Hill, E. Betz

DATE OF ANALYSIS: 02/08/85  
ANALYSED BY: John L. Neal, Vicki Painter

DATE REPORTED: 02/08/85

RESULTS IN PPB (ug/L)

<u>LOCATION</u>	<u>trans 1,2-DCE</u>	<u>CHCl3</u>	<u>DCBM</u>	<u>TCE</u>	<u>DBCM</u>
Bldg. 20 Res. Fin. Water	5.3	10.3	6.3	16.8	3.4
Bldg. 20 Filter Eff.#1	<2.0	6.8	4.3	<2.0	2.0
Bldg. 20 Filter Eff.#2	<2.0	9.1	5.7	3.4	3.4
Bldg. 20 Influent	<2.0	5.0	4.0	<2.0	1.5
Bldg. 670 Res. Fin. Water	<2.0	14.84	8.3	<2.0	3.6
Bldg. 670 Filter Eff.#1	<2.0	11.45	6.1	<2.0	1.2
Bldg. 670 Filter Eff.#2	<2.0	10.03	5.8	<2.0	1.2
Bldg. 670 Influent	<2.0	8.1	4.9	<2.0	1.7
MOQ 2204 Hydr. Dis. Sys.	9.0	23.92	10.74	32.4	4.5
Bldg. 5400 Ber. Man. Sch.	44.8	24.49	10.83	135.1	5.0

COMMENTS: trans 1,2-DCE is trans 1,2-dichloroethylene, CHCl3 is Chloroform, DCBM is dichlorobromomethane, TCE is trichloroethylene, and DBCM is dibromochloromethane. Samples analysed by purge and trap method utilizing Hall detector in the halogen mode.

REPORTED BY: John L. Neal

cc. Charles Rundgren, Water Supply Branch  
Mike Bell, ERO  
J. Fred Hill, ERO  
Environmental Epidemiology

CLW

000004517

2-8-85 from D. Shupe

~~BA-164~~ BA-164 - none  
BA-190 - none

BB-43 - out  
BB-44 - none  
BB-220 - none  
BB-221 - none  
BB-97 - not sampled  
A-5 - TTHM's 50 PPB.

New Well C+B.  
ISO Propyl Alcohol  
Acetone

M-142 - none  
M-168 - out  
M-197 - none  
267 - none  
628 - none  
629 - none  
630 - none

TT-25 - none

26 - TCE 57	27 PPB - Vinyl Chloride
1,2 Di - 92	
Tetra - 1580	

TT-30 - none  
TT-31 - none  
52 - none  
54 - none  
67 - none  
~~78~~ -

CLW  
0000004518

TT - New Well - 5.8 TCE  
11.0 Trihalo, 1,2

Tetra - 132