WATER SYSTEM: ONSLOW BEACH

UNITS: ppb	WATER TREATMENT PLANT, BLDG BA-138					BLDG BA-103 MESS HALL					CAMPSITE #2 SPIGOT 10 (MAINLAND)					CAMPSITE #1 SPIGOT 2 (BEACHSIDE)					BLDG SBA 142 PIER					AVERAGE	
DATE	$CHCl_3$	$CHCl_2Br$	$CHClBr_2$	$CHBr_3$	TTHM	$CHCl_3$	$CHCl_2Br$	$CHClBr_2$	$CHBr_3$	TTHM	$CHCl_3$	$CHCl_2Br$	$CHClBr_2$	$CHBr_3$	TTHM	$CHCl_3$	$CHCl_2Br$	$CHClBr_2$	$CHBr_3$	TTHM	$CHCl_3$	$CHCl_2Br$	$CHClBr_2$	$CHBr_3$	TTHM	MON	QTR
AUGUST 1983	12	2	<1	<1	14	~~40~~ NO SAMPLES	~~5~~	~~2~~	~~<1~~	~~47~~	40	5	2	<1	47	41	10	2	<1	53	20	<1	<1	<1	20		

* HOLDING TIME BETWEEN COLLECTION AND ANALYSIS EXCEEDED 14 DAYS

RED SHADED BOXES CONTAIN VALUES EXCEEDING THE 100 PPB (0.1 mg/l) LIMIT

CLW

00000006428

WATER SYSTEM: ONSLOW BEACH

TTHM PPB	WATER TREATMENT PLANT, BLDG BA-138					BLDG BA-103 MESS HALL					CAMPSITE #2 SPIGOT 10 (MAINLAND)					CAMPSITE #1 SPIGOT 2 (BEACHSIDE)					BLDG SBA-142 PIER					AVERAGE	
DATE	$CHCl_3$	$CHCl_2Br$	$CHClBr_2$	$CHBr_3$	mg/l TTHM	$CHCl_3$	$CHCl_2Br$	$CHClBr_2$	$CHBr_3$	mg/l TTHM	$CHCl_3$	$CHCl_2Br$	$CHClBr_2$	$CHBr_3$	mg/l TTHM	$CHCl_3$	$CHCl_2Br$	$CHClBr_2$	$CHBr_3$	mg/l TTHM	$CHCl_3$	$CHCl_2Br$	$CHClBr_2$	$CHBr_3$	mg/l TTHM	mg/l MON	mg/l QTR.
APRIL 1982	32	9	1	<1	42 0.04	41	10	2	<1	53 <0.05	32	9	1	<1	42 <0.04	39	6	<1	<1	45 <0.05	29	9	1	<1	39 <0.04	44.2 <0.05	—
MAY 1982	24	7	1	<1	32 0.03	36	9	2	<1	47 0.05	47	11	3	<1	61 0.06	42	7	1	<1	50 0.05	35	6	1	<1	42 0.04	46.4 0.05	0.05
JUNE 1982	35	8	1	<1	44 0.05	46	11	2	<1	59 0.06	54	11	3	<1	68 0.07	61	11	3	<1	65 0.07	54	12	2	<1	69 0.07	60.8 0.07	
JULY 1982	8	2	1	<1	11 0.01	34	9	2	<1	45 0.05	30	7	1	<1	38 0.04	35	9	2	<1	46 0.05	38	10	2	<1	50 0.05	38 0.05	
AUGUST 1982	No	SAMPLES																									0.06
SEPTEMBER 1982	No	SAMPLES																									
OCTOBER 1982	No	SAMPLES																									
NOVEMBER 1982	20	5	2	<1	27 0.03	28	3	1	<1	32 0.03	32	7	1	<1	40 0.04	38	5	1	<1	44 0.04	37	3	<1	<1	40 0.04	36.6 0.04	0.04
DECEMBER 1982	No	SAMPLES																									
JANUARY 1983	No	SAMPLES																									
FEBRUARY 1983	32 ~~No~~	9	3	<1	44 0.04	No	SAMPLES																				
MARCH 1983	No	SAMPLES																									
APRIL 1983	No	SAMPLES																									
MAY 1983	23	7	2	<1	32	No	SAMPLE				27	8	1	<1	36	42	12	2	<1	54	26	2	<1	<1	28		
JUNE 1983	No	SAMPLES																									
JULY 1983	No	SAMPLES																									

HOLDING TIME BETWEEN COLLECTION AND ANALYSIS EXCEEDED 14 DAYS.

ED SHADED BOXES CONTAIN VALUES EXCEEDING THE 100 PPB (0.1 mg/l) LIMIT

MAR - A 45.5

APR - J 50.5

JUN - A APR - 49.

JUL - A 38.0

SEP - N 36.6

OCT - D 36.6

DEC - A 44

JAN

CLW

00000064 28