## SONGS Unit 3 Steam Generators Wear Depths Summary

Steam Generator SG3E88 (Through- Wall Wear)	Anti-Vibration Bar	Tube Support Plate	Tube-to-Tube Wear	Retainer Bar	Foreign Object	Total Indications	Tubes with Indications (out of 9727 total per SG)
≥ 50%	0	117	48	0	0	165	74
35 - 49%	3	217	116	2	0	338	119
20 - 34%	156	506	134	1	0	797	197
10 - 19%	1380	542	98	0	0	2020	554
< 10%	1818	55	11	0	0	1884	817
TOTAL	3357	1437	407	3	0	5204	919*

Steam Generator SG3E89 (Through- Wall Wear)	Anti-Vibration Bar	Tube Support Plate	Tube-to-Tube Wear	Retainer Bar	Foreign Object	Total Indications	Tubes with Indications (out of 9727 total per SG)
≥ 50%	0	91	26	0	0	117	60
35 - 49%	0	252	102	1	0	355	128
20 - 34%	45	487	215	0	0	747	175
10 - 19%	940	590	72	0	0	1602	450
< 10%	2164	94	1	0	0	2259	838
TOTAL	3149	1514	416	1	0	5080	887*

<sup>\*</sup> This value is the number of tubes with wear indications at any depth and at any location. Since many tubes have indications in more than one depth and locations, the total number of tubes is less than the total number of indications.

<sup>\*</sup> This value is the number of tubes with wear indications at any depth and at any location. Since many tubes have indications in more than one depth and locations, the total number of tubes is less than the total number of indications.